



JEFFERSON PARISH LOUISIANA

PURCHASING DEPARTMENT

May 17, 2010

ADDENDUM #2

Our Mission Is:
"Provide the services,
leadership, and vision to
improve the quality of life
in Jefferson Parish."

STEVE J. THERIOT
PARISH PRESIDENT

PATRICIA W. LASSALLE
PURCHASING DIRECTOR

Bid No.: 50-97229

Bid Opening Date: 05/06/2010

For: PURCHASE OF A QUANTITY OF VALVES, (KNIFE, CHECK & GATE), AND DUCTILE
IRON PIPE FOR THE JEFFERSON PARISH DEPARTMENT OF PUBLIC WORKS,
SEWERAGE

**PLEASE NOTE THE FOLLOWING ADDITIONAL INFORMATION CONCERNING THE
BID SPECIFICATIONS AND ADJUST YOUR BID ACCORDINGLY.**

ADD the following additional specifications to Item 3 - 0030 – Pipe, ductile iron, 12 inch.

**The factory applied interior coating/lining shall be PROTECTO 401 ceramic epoxy with
factory asphaltic exterior coating. Polyethylene encasement in accordance with ANSI/AWWA
C105/A21.5 shall be supplied with ductile iron pipe.**

BID OPENING DATE IS BEING POSTPONED TO 5/25/2010

**THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE ORIGINAL BIDDING
DOCUMENTS AND SPECIFICATIONS. THE CONTENTS OF THIS ADDENDUM SHALL BE INCLUDED IN THE
CONTRACT DOCUMENTS. CHANGES MADE BY THIS ADDENDUM SHALL TAKE PRECEDENCE OVER THE
DOCUMENTS OF EARLIER DATE.**

Sincerely,

Stella Vasquez, Buyer II
JP Purchasing Department

PLEASE SIGN AND RETURN THIS ADDENDUM IN ITS ENTIRETY WITH THE BID PROPOSAL:

COMPANY NAME: _____

SIGNATURE: _____

DATE: _____